



# JAGDAMBA LABORATORIES (OPC) PVT. LTD.

(Formerly Known as Jagdamba Laboratories)

Govt. Approved Test House • ISO 9001: 2015 • GLP Certified Lab.

119, Solitaire Industrial Park, Phase-1<sup>st</sup>, Dahmi Kallan, Bagru, Jaipur - 303007 (Rajasthan)  
Tel. : 0141-2390604 Email : jagdambalab4@gmail.com, jagdamba\_lab@yahoo.com Web : jagdambalab.com

TESTING OF WATER | FOODS | ALCOHOLIC DRINKS | DRUGS | HERBALS | COSMETICS | CHEMICALS | MINERALS | BUILDING MATERIAL | METALS

## TEST REPORT

ULR No. : TC1183726000001968F

|                       |   |                  |        |
|-----------------------|---|------------------|--------|
| Sample Name           | BOREWELL WATER  |                  |        |
| Report No.            | JLWT260213008   | Batch No.        | NA     |
| Ref. No.              | 4155 Dt: 13.02.2026   | Mfg. Date        | NA     |
| Date of Received      | 13/02/2026  | Exp. Date        | NA     |
| Started of Analysis   | 13/02/2026  | Sample Condition | OK     |
| End of Analysis       | 14/02/2026  | Sample Qty.      | 1 Ltr. |
| Report Release Date   | 14/02/2026  | Sample Code      | NA     |
| Sample Submitted By   | PRINCIPAL NEERJA MODI SCHOOL MAHENDRA SEZ, KALWARA, JAIPUR                  |                  |        |
| Test Report Issued to | PRINCIPAL NEERJA MODI SCHOOL<br>MAHENDRA SEZ, KALWARA, JAIPUR RAJASTHAN     |                  |        |
| Environment Condition | Temperature (°C) - As per Standard, Relative Humidity (%) - As per Standard |                  |        |

### TEST RESULTS

Reference : As per IS 10500-2012 (Second Revision)

Description : Colourless Liquid.

| Sl. No.  | Test Parameters                        | Unit       | Test Results | Requirement Acceptable Limit (Max) | Limits in Absence of alternate Source (Max) | Test Method                                    |
|--|--|------------|--------------|------------------------------------|---|--|
| <b>A : ORGANOLEPTIC &amp; PHYSICAL PARAMETERS</b>  |  |            |              |                                    |   |  |
| 1  | Color                                  | Hazen Unit | <5           | Max 5                              | Max 15                                      | IS 3025 (Part-4)                               |
| 2  | Turbidity                              | N.T.U      | <1           | Max 1                              | Max 5                                       | IS 3025 (Part-10)                              |
| 3  | pH                                     | -          | 7.92         | 6.5-8.5                            | No Relaxation                               | IS 3025 (Part-11)                              |
| 4  | Total Dissolved Solids(T.D.S.)         | mg/ltr     | 3654         | Max 500                            | Max 2000                                    | IS 3025 (Part-16)                              |
| <b>B. GENERAL &amp; TOXIC SUBSTANCE PARAMETERS</b> |  |            |              |                                    |   |  |
| 1  | Iron(as Fe)                            | mg/ltr     | 0.90         | Max 1.0                            | No Relaxation                               | IS 3025(Part- 53)                              |
| 2  | Chloride(as Cl)                        | mg/ltr     | 1221.35      | Max 250                            | Max 1000                                    | IS 3025(Part 32)                               |
| 3  | Total Hardness (as CaCO <sub>3</sub> ) | mg/ltr     | 393.12       | Max 200                            | Max 600                                     | IS 3025(Part 21)                               |
| 4  | Calcium(as Ca)                         | mg/ltr     | 90.94        | Max 75                             | Max 200                                     | IS 3025(Part 40)                               |
| 5  | Magnesium (as Mg)                      | mg/ltr     | 40.17        | Max 30                             | Max 100                                     | IS 3025(Part 46)                               |
| 6  | Sulphate(as SO <sub>4</sub> )          | mg/ltr     | 488.86       | Max 200                            | Max 400                                     | IS 3025 (Part 24)                              |
| 7  | Fluoride (as F)                        | mg/ltr     | 1.40         | Max 1.0                            | Max 1.5                                     | APHA 24th Edition 4500-F D Page No. 400 to 401 |
| 8  | Nitrate (as NO <sub>3</sub> )          | mg/ltr     | 108.0        | Max 45                             | No Relaxation                               | IS 3025 (Part 34/Sec 1)                        |

14/02/26

Review by

Gajanand Kumawat

Dy. Technical Manager- Food



Adt

Authorised Signatory  
Kuldeep Singh

Technical Manager-Chemical

Page No.1 of 2

#### NOTE :

- This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without special permission in writing
- Total liability of this Laboratory is limited to the invoice amount.
- This results listed refer only to the above sample and applicable parameter's Endorsement of products is neither inferred nor implied.
- Sample will be destroyed after one month (In case of nonperishable items only) the date of issue of test certificate unless otherwise specified.
- Report refer to the Sample Submitted to us and not drawn by Jagdamba Laboratories (OPC) Pvt. Ltd. unless mentioned otherwise.





TC-11837

# JAGDAMBA LABORATORIES (OPC) PVT. LTD.

(Formerly Known as Jagdamba Laboratories)

Govt. Approved Test House • ISO 9001: 2015 • GLP Certified Lab.

119, Solitaire Industrial Park, Phase-1<sup>st</sup>, Dahmi Kallan, Bagru, Jaipur - 303007 (Rajasthan)  
 Tel. : 0141-2390604 Email : jagdambalab4@gmail.com, jagdamba\_lab@yahoo.com Web : jagdambalab.com

TESTING OF WATER | FOODS | ALCOHOLIC DRINKS | DRUGS | HERBALS | COSMETICS | CHEMICALS | MINERALS | BUILDING MATERIAL | METALS



## TEST REPORT

ULR No. : TC118372600001968F

|                       |   |                  |        |
|-----------------------|---|------------------|--------|
| Sample Name           | BOREWELL WATER  |                  |        |
| Report No.            | JLWT260213008   | Batch No.        | NA     |
| Ref. No.              | 4155 Dt: 13.02.2026   | Mfg. Date        | NA     |
| Date of Received      | 13/02/2026  | Exp. Date        | NA     |
| Started of Analysis   | 13/02/2026  | Sample Condition | OK     |
| End of Analysis       | 14/02/2026  | Sample Qty.      | 1 Ltr. |
| Report Release Date   | 14/02/2026  | Sample Code      | NA     |
| Sample Submitted By   | PRINCIPAL NEERJA MODI SCHOOL MAHENDRA SEZ, KALWARA, JAIPUR                  |                  |        |
| Test Report Issued to | PRINCIPAL NEERJA MODI SCHOOL<br>MAHENDRA SEZ, KALWARA, JAIPUR RAJASTHAN     |                  |        |
| Environment Condition | Temperature (°C) - As per Standard, Relative Humidity (%) - As per Standard |                  |        |

### TEST RESULTS

Reference : As per IS 10500-2012 (Second Revision)

Description : Colourless Liquid.

| Sl. No. | Test Parameters                         | Unit   | Test Results | Requirement Acceptable Limit (Max) | Limits in Absence of alternate Source (Max) | Test Method      |
|---------|---|--------|--------------|------------------------------------|---|------------------|
| 9       | Total Alkalinity(as CaCO <sub>3</sub> ) | mg/ltr | 1194.0       | Max 200                            | Max 600                                     | IS 3025(Part 23) |

The above sample not confirms to As per IS 10500-2012 (Second Revision) with respect to the above tests only.

\*\*\*END OF REPORT\*\*\*

*[Signature]*  
14/02/26,  
Review by

Gajanand Kumawat  
Dy. Technical Manager- Food



*A det.*  
PRINCIPAL  
NEERJA MODI SCHOOL  
KALWARA, JAIPUR

*[Signature]*  
Authorised Signatory  
Kuldeep Singh  
Technical Manager-Chemical

Page No 2 of 2

#### NOTE :

- This report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without special permission in writing
- Total liability of this Laboratory is limited to the invoice amount.
- This results listed refer only to the above sample and applicable parameter's Endorsement of products is neither inferred nor implied.
- Sample will be destroyed after one month (In case of nonperishable items only) the date of issue of test certificate unless otherwise specified.
- Report refer to the Sample Submitted to us and not drawn by Jagdamba Laboratories (OPC) Pvt. Ltd. unless mentioned otherwise.

